Energy Performance Certificate

Address of dwelling and other details

1 MARINE PARADE. INN STREET. TAYPORT. **DD6 9BF**

Dwelling type:

Ground-floor flat

Elmhurst Energy Systems Ltd Name of approved organisation:

Membership number: Date of certificate:

EES/006747

12 August 2010

0118-1011-7208-7110-1900

Reference number: Type of assessment: Total floor area:

RdSAP, existing dwelling

56 m²

Main type of heating and fuel:

Boiler and radiators, mains gas

This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2005 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO2) emissions. CO2 is a greenhouse gas that contributes to climate change.

						Current	Potential
Very energy efficie (92 plus)	nt - Io wel	running (costs				
(81-91)	B						
(69-80)		C				73	76
(55-68)		D					
(39-54)			置			-	
(21-38)				F			
(1-20)					G		
Not energy efficient	t - higher	running o	costs				

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

Environmental Impact (CO2) Rating Current Potential Very environmentally fitendly - lower CO2 emissions A (92 plus) B (81-91) C 75 (69-80) 773 1 (55-68) 匡 /39.54 F G Not environmentally friendly - higher CO2 emissions **EU Directive** Scotland 2002/91/EC

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO2) emissions. The higher the rating the less impact it has on the environment.

Approximate current energy use per square metre of floor area: 225 kWh/m² per year Approximate current CO2 emissions: 37 kg/m² per year

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above. Higher cost measures could also be considered and these are recommended in the attached energy report.

1 Low energy lighting for all fixed outlets

2 Upgrade heating controls

A full energy report is appended to this certificate



N.R. THIS CEPTIFICATE MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED VERSION

12 August 2010

RRN:

0118-1011-7208-7110-1900

Energy Report



The Energy Performance Certificate and Energy Report for this dwelling were produced following an energy assessment undertaken by a member of Elmhurst Energy Systems Ltd. This is an organisation which has been approved by the Scottish Ministers. The certificate has been produced under the Building (Scotland) Amendment Regulations 2006 and a copy of the certificate and this energy report have been lodged on a national register.

Assessor's name:

Mr. Frank Ernest White

Company name/trading name:

Rosebum Energy

Address:

27 Naughton Road, Wormit, Fife, DD6 8NE

Phone number:

01382 542904

Fax number:

E-mail address:

shoniefrank@gmail.com

Related party disclosure:

No related party

Estimated energy use, carbon dioxide (CO2) emissions and fuel costs of this home

	Current	Potential
Energy use	225 kWh/m² per year	204 kWh/m² per year
Carbon dioxide emissions	2.1 tonnes per year	1.9 tonnes per year
Lighting	£60 per year	£33 per year
Heating	£344 per year	£336 per year
Hot water	£99 per year	£93 per year

The figures in the table above have been provided to enable prospective buyers and tenants to compare the fuel costs and carbon emissions of one home with another. To enable this comparison the figures have been calculated using standardised running conditions (heating periods, room temperatures, etc.) that are the same for all homes, consequently they are unlikely to match an occupier's actual fuel bills and carbon emissions in practice. The figures do not include the impacts of the fuels used for cooking or running appliances, such as TV, fridge etc.; nor do they reflect the costs associated with service, maintenance or safety inspections. Always check the certificate date because fuel prices can change over time and energy saving recommendations will evolve.

About the building's performance ratings

The ratings on the certificate provide a measure of the building's overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used.

Not all buildings are used in the same way, so energy ratings use 'standard occupancy' assumptions which may be different from the specific way you use your home.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings in the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.

RRN:

0118-1011-7208-7110-1900

Summary of this home's energy performance related features

The table below gives an assessment of the key individual elements that have an impact on this home's energy and environmental performance. Each element is assessed by the national calculation methodology against the following scale: Very poor / Poor / Average / Good / Very good. The assessment does not take into consideration the physical condition of any element. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology based on age and type of construction.

	mption has been made in the methodology based on	Current performance		
Elements	Description	Energy Efficiency	Environmental	
Walls	Timber frame, as built, insulated (assumed)	Good	Good	
Roof	(another dwelling above)	-	•	
Floor	Suspended, insulated (assumed)	-		
Windows	Fully double glazed	Average	Average	
Main heating	Boiler and radiators, mains gas	Good	Good	
Main heating controls	Programmer, TRVs and bypass	Average	Average	
Secondary heating	Room heaters, electric		-	
Hot water	From main system	Good	Good	
Lighting	Low energy lighting in 15% of fixed outlets	Poor	Poor	
Current energy	efficiency rating	C 73		
	mental impact (CO2) rating		C 73	
Current environ	mental impact (CO2) fating			

Low and zero carbon energy sources

These are sources of energy (producing or providing electricity or hot water) which emit little or no carbon dioxide into the atmosphere. There are none applicable to this home.

RRN:

0118-1011-7208-7110-1900

Recommended measures to improve this home's energy performance

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table. However you should check the conditions in any covenants, warranties or sale contracts, and whether any legal permissions are required such as a building warrant, planning consent or listed building restrictions.

	Typical savings	Performance ratings after improvement	
Lower cost measures (up to £500)	per year	Energy efficiency	Environmental impact
Low energy lighting for all fixed outlets	£21	C 75	C 73
2 Upgrade heating controls	£22	C 76	C 75
Sub-total	£43		
Higher cost measures (over £500)			
3 Replace boiler with new condensing boiler	£33	C 78	C 78
	£76		
Total	2.70		
Potential energy efficiency rating	2/0	C 78	

Further measures to achieve even higher standards

None

Improvements to the energy efficiency and environmental impact ratings will usually be in step with each other. However, they can sometimes diverge because reduced energy costs are not always accompanied by a reduction in carbon dioxide (CO₂) emissions.

RRN:

0118-1011-7208-7110-1900

About the cost effective measures to improve this home's performance ratings

If you are a tenant, before undertaking any work you should check the terms of your lease and obtain approval from your landlord if the lease either requires it, or makes no express provision for such work.

Lower cost measures (typically up to £500 each)

These measures are relatively inexpensive to install and are worth tackling first. Some of them may be installed as DIY projects. DIY is not always straightforward, and sometimes there are health and safety risks, so take advice before carrying out DIY improvements.

1 Low energy lighting

Replacement of traditional light bulbs with energy saving recommended ones will reduce lighting costs over the lifetime of the bulb, and they last up to 12 times longer than ordinary light bulbs. Also consider selecting low energy light fittings when redecorating; contact the Lighting Association for your nearest stockist of Domestic Energy Efficient Lighting Scheme fittings.

2 Heating controls (room thermostat)

The heating system should have a room thermostat to enable the boiler to switch off when no heat is required. A competent heating engineer should be asked to do this work. Insist that the thermostat switches off the boiler as well as the pump and that the thermostatic radiator valve is removed from any radiator in the same room as the thermostat. Building regulations may apply to this work, so it is best to obtain advice from your local authority building standards department and from a qualified heating engineer.

Higher cost measures (typically over £500 each)

3 New condensing boiler

A condensing boiler is capable of much higher efficiencies than other types of boiler, meaning it will burn less fuel to heat this property. This improvement is most appropriate when the existing central heating boiler needs repair or replacement, but there may be exceptional circumstances making this impractical. Condensing boilers need a drain for the condensate which limits their location; remember this when considering remodelling the room containing the existing boiler even if the latter is to be retained for the time being (for example a kitchen makeover). Building regulations may apply to this work, so it is best to obtain advice from your local authority building standards department and from a qualified heating engineer.

About the further measures to achieve even higher standards

Not applicable

What can I do today?

Actions that will save money and reduce the impact of your home on the environment include:

- Ensure that you understand the dwelling and how its energy systems are intended to work so as to obtain the maximum benefit in terms of reducing energy use and CO2 emissions.
- If you have a conservatory or sunroom, avoid heating it in order to use it in cold weather and close doors between the conservatory and dwelling.
- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.
- If you're not filling up the washing machine, tumble dryer or dishwasher, use the half-load or economy programme. Minimise the use of tumble dryers and dry clothes outdoors where possible.
- Close your curtains at night to reduce heat escaping through the windows.

For advice on how to take action and to find out about offers available to help make your home more energy efficient, call 0800 512 012 or visit www.energysavingtrust.org.uk.