

## Automatic Fire Detection & Fire Alarm System Test Certificate



www.davidlove.co.uk    0131 6549960    info@davidlove.co.uk

Client Name:	Cornerstone Letting	Site Address:	24 F28, Simpson Loan, Edinburgh, EH3 9GD		
Extent of the fire detection system			Only the flat named above. Communal stairway not included. Other properties in the block are not linked.		
System description			Two smoke detector alarms in the hall. One Multi detector alarm in the Living Room/Kitchen.		
Hard wired			Yes		
Interlinked			Yes		
Mains powered			Yes		
Battery backup			Yes		
Wireless			No		
Remote signalling			No		
All equipment operates correctly			Yes		
Complies with BS 5839-1:-2017			Yes		
Instructions available for the user			No		
Expiration dates			Hall 2028 Living Room/Kitchen 2028		
<p>I being the competent person responsible for the testing of the fire detection equipment and the fire alarm system, certify that the said testing for which I have been responsible complies to the best of my knowledge and belief with the recommendations of Clause 39 of BS 5839-1:2017, except for the variations (if any) stated in this certificates</p>					
Tester:	David Love	Signature:	<i>David Love</i>	Date:	18th November 2020
Variations from the recommendations of Clause 39 of BS 5839-1:2017					None