



# H. F. ELECTRICAL LTD



8 HARRISON LANE, EDINBURGH, EH11 1HG

Phone 0131 337 4011

Fax 0131 313 2799

e-mail hfelec@hfelec.co.uk

## CERTIFICATE OF TEST

OF

### PORTABLE ELECTRICAL APPARATUS


Apparatus Ref No (s)	As Per Attached Schedule
Description	As Per Attached Schedule
Location	2/7 Drybrough Crescent Edinburgh


The above apparatus has been inspected and tested in accordance with the requirements of the Health and Safety Executive Guidance Note PM32 (1990) and the Institution of Electrical Engineers Code of Practice for In-Service Inspection and Testing of Electrical Equipment (1994)

Test Results on apparatus and power leads are shown on appliance sheet(s) numbers  
As Per Attached Schedule

Date of Test 08-Oct-12

Recommended Date of next Inspection for Appliances 08-Oct-13

Signed 	Date	8-Oct-12	Status		Contract Manager
--	------	----------	--------	--	------------------

For and on Behalf of  <b>ELECTRICAL</b>	Hugh Fulton Electrical Ltd 8 Harrison Lane Edinburgh EH11 1HG
---	--

Works Carried out under Instruction from  <b>Dunpark</b>	Dunpark Ltd 1 Abercromby Place Edinburgh EH3 6JX
--	---

Asset Number from 222302001 to 222302008 Sequence = Asset Number

DUNPARK				
Asset Number	Asset Type	Description	Site	Location
222302001	PATS	Kettle	2/7 DRYBROUGH CRESC	Kitchen
222302002	PATS	Dishwasher	2/7 DRYBROUGH CRESC	Kitchen
222302003	PATS	Iron	2/7 DRYBROUGH CRESC	Kitchen
222302004	PATS	Standard Lamp	2/7 DRYBROUGH CRESC	Living Room
222302005	PATS	Table Lamp	2/7 DRYBROUGH CRESC	Living Room
222302006	PATS	Table Lamp	2/7 DRYBROUGH CRESC	Living Room
222302007	PATS	Washing Machine	2/7 DRYBROUGH CRESC	Hall Cupboard
222302008	PATS	Hoover	2/7 DRYBROUGH CRESC	Hall Cupboard 2

Total Number of Assets 8

M:

Asset Number from 222302001 to 222302008, Include all tests

DUNPARK		Site: 2/7 DRYBROUGH CRESC			Location : Hall Cupboard		
Asset Number	Serial Number						
Description							
Test Type	Date Done	Result	Reading	Value	Unit	Result	Comment
222302007			Test Mode	AUTO		Information	
Washing Machine			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current	26	A	Information	
			Earth	0.11	OHM	Pass	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	0.0	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Skip	

DUNPARK		Site: 2/7 DRYBROUGH CRESC			Location : Hall Cupboard 2		
Asset Number	Serial Number						
Description							
Test Type	Date Done	Result	Reading	Value	Unit	Result	Comment
222302008			Test Mode	AUTO		Information	
Hoover			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current		A	Information	
			Earth		OHM	Skip	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	1.8	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Skip	

DUNPARK		Site: 2/7 DRYBROUGH CRESC			Location : Kitchen		
Asset Number	Serial Number						
Description							
Test Type	Date Done	Result	Reading	Value	Unit	Result	Comment
222302001			Test Mode	AUTO		Information	
Kettle			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current	26	A	Information	
			Earth	0.03	OHM	Pass	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	2.2	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Pass	

222302002			Test Mode	AUTO		Information	
Dishwasher			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current	26	A	Information	
			Earth	0.04	OHM	Pass	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	0.0	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Pass	

Asset Number from 222302001 to 222302008, Include all tests

DUNPARK		Site: 2/7 DRYBROUGH CRESC			Location : Kitchen		
Asset Number	Serial Number						
Description							
Test Type	Date Done	Result	Reading	Value	Unit	Result	Comment
222302003			Test Mode	AUTO		Information	
Iron			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current	26	A	Information	
			Earth	0.08	OHM	Pass	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	1.4	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Pass	

DUNPARK		Site: 2/7 DRYBROUGH CRESC			Location : Living Room		
Asset Number	Serial Number						
Description							
Test Type	Date Done	Result	Reading	Value	Unit	Result	Comment
222302004			Test Mode	AUTO		Information	
Standard Lamp			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current		A	Information	
			Earth		OHM	Skip	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	0.0	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Skip	

222302005			Test Mode	AUTO		Information	
Table Lamp			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current		A	Information	
			Earth		OHM	Skip	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	0.0	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Skip	

222302006			Test Mode	AUTO		Information	
Table Lamp			Visual Check			Pass	
Full Test	08/10/2012	PASS	Earth Current		A	Information	
			Earth		OHM	Skip	
			Insulation	>20	MEG	Pass	
			Flash Test		mA	Skip	
			Load	0.0	KVA	Pass	
			Leakage	0.0	mA	Pass	
			Lead Check			Skip	