

Energy Performance Certificate

Address of dwelling and other details

10 WHINWELL ROAD,
STIRLING,
FK8 1EZ

Dwelling type:
Name of approved organisation:
Membership number:
Date of certificate:
Reference number:
Total floor area:
Main type of heating and fuel:

Ground-floor flat
Elmhurst Energy Systems Ltd
EES/007166
07 October 2009
9140-2213-4000-0601-2261
55 m²
Electric storage heaters

This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2005 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO₂) emissions. CO₂ is a greenhouse gas that contributes to climate change.

Energy Efficiency Rating		
	Current	Potential
<div style="text-align: right; font-size: small;">Very energy efficient - lower running costs</div> <div style="text-align: center;"> <div style="background-color: #004a99; color: white; padding: 2px; margin-bottom: 2px;">(92 plus) A</div> <div style="background-color: #006699; color: white; padding: 2px; margin-bottom: 2px;">(81-91) B</div> <div style="background-color: #008099; color: white; padding: 2px; margin-bottom: 2px;">(69-80) C</div> <div style="background-color: #009999; color: white; padding: 2px; margin-bottom: 2px;">(65-68) D</div> <div style="background-color: #00b099; color: white; padding: 2px; margin-bottom: 2px;">(59-64) E</div> <div style="background-color: #00c099; color: white; padding: 2px; margin-bottom: 2px;">(51-58) F</div> <div style="background-color: #00d099; color: white; padding: 2px; margin-bottom: 2px;">(41-50) G</div> </div> <div style="text-align: left; font-size: small;">Not energy efficient - higher running costs</div>	65	65
<div style="display: flex; justify-content: space-between;"> Scotland EU Directive 2002/91/EC </div>		

Environmental Impact (CO ₂) Rating		
	Current	Potential
<div style="text-align: right; font-size: small;">Very environmentally friendly - lower CO₂ emissions</div> <div style="text-align: center;"> <div style="background-color: #004a99; color: white; padding: 2px; margin-bottom: 2px;">(92 plus) A</div> <div style="background-color: #006699; color: white; padding: 2px; margin-bottom: 2px;">(81-91) B</div> <div style="background-color: #008099; color: white; padding: 2px; margin-bottom: 2px;">(69-80) C</div> <div style="background-color: #009999; color: white; padding: 2px; margin-bottom: 2px;">(65-68) D</div> <div style="background-color: #00b099; color: white; padding: 2px; margin-bottom: 2px;">(59-64) E</div> <div style="background-color: #00c099; color: white; padding: 2px; margin-bottom: 2px;">(51-58) F</div> <div style="background-color: #00d099; color: white; padding: 2px; margin-bottom: 2px;">(41-50) G</div> </div> <div style="text-align: left; font-size: small;">Not environmentally friendly - higher CO₂ emissions</div>	56	56
<div style="display: flex; justify-content: space-between;"> Scotland EU Directive 2002/91/EC </div>		

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the energy bills are likely to be.

Approximate current energy use per square metre of floor area: 402 kWh/m² per year

Approximate current CO₂ emissions: 61 kg/m² per year

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating the less impact it has on the environment.

Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above. Higher cost measures could also be considered and these are recommended in the attached energy report.

Not applicable

A full energy report is appended to this certificate

Information from this EPC may be given to Energy Saving Trust to provide advice to householders on financial help available to improve home energy efficiency.

For advice on how to take action and to find out about offers available to make your home more energy efficient, call 0800 512 012 or visit www.energysavingtrust.org.uk

N.B. THIS CERTIFICATE MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED VERSION

Energy Report

The Energy Performance Certificate and Energy Report for this dwelling were produced following an energy assessment undertaken by a member of Elmhurst Energy Systems Ltd. This is an organisation which has been approved by the Scottish Ministers. The certificate has been produced under the Building (Scotland) Amendment Regulations 2006 and a copy of the certificate and this energy report have been lodged on a national register.

Assessor's name: Mr. Gerard McInerney
 Company name/trading name: Pepaco Process Management
 Address: DCS House, Silverbirch Mylord Crescent, Camperdown Industrial Estate, Newcastle Upon Tyne, NE12 5UJ
 Phone number: 0191 2560021
 Fax number: 0191 256 0020
 E-mail address: j.mci@talktalk.net
 Related party disclosure:

Estimated energy use, carbon dioxide (CO₂) emissions and fuel costs of this home

	Current	Potential
Energy use	402 kWh/m ² per year	402 kWh/m ² per year
Carbon dioxide emissions	3.3 tonnes per year	3.3 tonnes per year
Lighting	£36 per year	£36 per year
Heating	£343 per year	£343 per year
Hot water	£113 per year	£113 per year

Based on standardised assumptions about occupancy, heating patterns and geographical location, the above table provides an indication of how much it will cost to provide lighting, heating and hot water to this home. The fuel costs only take into account the cost of fuel and not any associated service, maintenance or safety inspection. This certificate has been provided for comparative purposes only and enables one home to be compared with another. Always check the date the certificate was issued, because fuel prices can increase over time and energy saving recommendations will evolve.

About the building's performance ratings

The ratings on the certificate provide a measure of the building's overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used.

Not all buildings are used in the same way, so energy ratings use 'standard occupancy' assumptions which may be different from the specific way you use your home.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings in the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.

Summary of this home's energy performance related features

The following is an assessment of the key individual elements that have an impact on this home's performance rating. Each element is assessed against the following scale: Very poor / Poor / Average / Good / Very good.

Elements	Description	Current performance	
		Energy Efficiency	Environmental
Walls	Cavity wall, as built, insulated (assumed)	Good	Good
Roof	(another dwelling above)	-	-
Floor	Suspended, no insulation (assumed)	-	-
Windows	Fully double glazed	Average	Average
Main heating	Electric storage heaters	Poor	Very poor
Main heating controls	Manual charge control	Poor	Poor
Secondary heating	Room heaters, electric	-	-
Hot water	Electric immersion, off-peak	Average	Poor
Lighting	Low energy lighting in 90% of fixed outlets	Very good	Very good
Current energy efficiency rating		D 65	
Current environmental impact (CO ₂) rating		D 56	

Low and zero carbon energy sources

These are sources of energy (producing or providing electricity or hot water) which emit little or no carbon dioxide into the atmosphere. There are none applicable to this home.

Recommended measures to improve this home's energy performance

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table. However you should check the conditions in any covenants, warranties or sale contracts, and whether any legal permissions are required such as a building warrant, planning consent or listed building restrictions.

Higher cost measures (over £500)	Typical savings per year	Performance ratings after improvement	
		Energy efficiency	Environmental impact
1 Fan-assisted storage heaters	£47	D 68	D 58
Total	£47		
Potential energy efficiency rating		D 68	
Potential environmental impact (CO₂) rating		D 58	

Further measures to achieve even higher standards

None

Improvements to the energy efficiency and environmental impact ratings will usually be in step with each other. However, they can sometimes diverge because reduced energy costs are not always accompanied by a reduction in carbon dioxide (CO₂) emissions.

About the cost effective measures to improve this home's performance ratings

If you are a tenant, before undertaking any work you should check the terms of your lease and obtain approval from your landlord if the lease either requires it, or makes no express provision for such work.

Higher cost measures (typically over £500 each)

1 Fan assisted storage heaters

Modern storage heaters are smaller and easier to control than the older type in the property. Ask for a quotation for new, fan-assisted heaters with automatic charge control. Installations should be in accordance with the current regulations covering electrical wiring. Building regulations may apply to this work, so it is best to obtain advice from your local authority building standards department and from a qualified heating engineer. Ask the heating engineer to explain the options, which might also include switching to other forms of electric heating.

About the further measures to achieve even higher standards

Not applicable

What can I do today?

Actions that will save money and reduce the impact of your home on the environment include:

- Ensure that you understand the dwelling and how its energy systems are intended to work so as to obtain the maximum benefit in terms of reducing energy use and CO₂ emissions.
- If you have a conservatory or sunroom, avoid heating it in order to use it in cold weather and close doors between the conservatory and dwelling.
- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Make sure your hot water is not too hot - a cylinder thermostat need not normally be higher than 60°C.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.
- If you're not filling up the washing machine, tumble dryer or dishwasher, use the half-load or economy programme. Minimise the use of tumble dryers and dry clothes outdoors where possible.
- Close your curtains at night to reduce heat escaping through the windows.