

SELECT
MEMBERSHIP
NUMBER
14265

This certificate is not valid if the
number is defaced or altered

EICR 190077

Copyright © The Electrical Contractors' Association of Scotland

SECTION A. DETAILS OF THE PERSON ORDERING THE REPORT

Name: **WINCHESTERS**
Address: **27 CLOVA CRESCENT, KINGSWELLS, ABERDEEN, AB15 8TJ**

SECTION B. REASON FOR PRODUCING THIS REPORT

Reason: **RENTAL INSPECTION**
Date(s) on which inspection and testing was carried out: **17/5/19**

SECTION C. DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier: **WINCHESTERS (UN OCCUPIED)**
Address: **27 CLOVA CRESCENT, KINGSWELLS, ABERDEEN, AB15 8TJ**
Description of premises (Tick as appropriate): Domestic ☒ Commercial ☐ Industrial ☐ Other ☐
Estimated age of the wiring system: **15** years. Evidence of additions or alterations Yes ☐ No ☒ Not apparent ☐
If "Yes" estimate age: years. Installation records available? (Regulation 651.1) Yes ☐ No ☐ Date of last inspection:

SECTION D. EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of the electrical installation covered by this report: **inspection and test of all circuits and accessories**
Agreed limitations including the reasons (Regulation 653.2): **NO R1+R2, NO INS. RESISTANCE. COULD NOT VERIFY CABLE CONDITION IN CONCEALED WALLS**
Agreed with (name): **WINCHESTERS**

Operational limitations including the reasons:
The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2018 (IET Wiring Regulations), as amended to It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground have **not** been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SECTION E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
Overall assessment of the installation in terms of its suitability for continued use
SATISFACTORY / UNSATISFACTORY* (Delete as appropriate)

*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

SECTION F. RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration.
Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by (date)

SECTION G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in Section D of this report.

Inspected and tested by:

Name (Capitals) **LEE FRASER**
Signature **[Signature]**
For/on behalf of **JOHN MUTCH**
Position **APPROVED ELECTRICIAN**
Address
Date

Report authorised for issue by:

Name (Capitals) **MUTCH**
Signature **[Signature]**
For/on behalf of **John Mutch Building Services Ltd**
Address **218 Holburn Street, Aberdeen, AB10 6DB**
phone: **01224 861999**
Date **21/5/19**

SECTION H. SCHEDULE(S)

..... schedule(s) of inspection and schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

SECTION I. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements	Number and Type of Live Conductors	Nature of Supply Parameters	Supply Protective Device Characteristics
TN-C	AC <input checked="" type="checkbox"/> DC <input type="checkbox"/>	Nominal voltage, $U/U_0^{(1)}$ 230 V	BS (EN): 1361
TN-S	1-phase, 2-wire <input checked="" type="checkbox"/> 2-wire <input type="checkbox"/>	Nominal frequency, $f^{(1)}$ 50 Hz	Type: IIb
TN-C-S	2-phase, 3-wire <input type="checkbox"/> 3-wire <input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)}$ kA	Rated current: 100 A
TT	3-phase, 3-wire <input type="checkbox"/> Other <input type="checkbox"/>	External loop impedance, $Z_e^{(2)}$ Ω	
IT	3-phase, 4-wire <input type="checkbox"/>		
	Confirmation of supply polarity <input type="checkbox"/>	(Note: (1) by enquiry, (2) by enquiry or by measurement)	
Other sources of supply <input type="checkbox"/>	(as detailed on attached schedule)		

SECTION J. PARTICULARS OF INSTALLATION REFERRED TO IN THE REPORT

Means of Earthing Distributor's facility <input type="checkbox"/> Installation earth electrode <input type="checkbox"/>		Details of Installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Location Electrode resistance to earth Ω			
Main Protective Conductors Earthing conductor: Material <u>Copper</u> csa <u>16</u> mm ² Connection / continuity verified <input type="checkbox"/> Main protective bonding conductors (to extraneous-conductive-parts): Material <u>Copper</u> csa <u>10</u> mm ² Connection / continuity verified <input type="checkbox"/> To water installation pipes <input type="checkbox"/> To gas installation pipes <input type="checkbox"/> To oil installation pipes <input type="checkbox"/> To structural steel <input type="checkbox"/> To lightning protection <input type="checkbox"/> To other <input type="checkbox"/> Specify:					
Main Switch / Switch-Fuse / Circuit-Breaker / RCD Location <u>Cupboard under Stair DB</u> Current rating <u>100</u> A If RCD main switch BS (EN) <u>5419</u> Fuse/device rating or setting <u>100</u> A Rated residual operating current ($I_{\Delta n}$) mA No. of poles <u>2</u> Voltage rating <u>240</u> V Rated time delay ms Measured operating time (at $I_{\Delta n}$) ms					

SECTION K. OBSERVATIONS

Referring to the attached Schedules of Inspection and Test Results, and subject to the limitations specified at Section D, Extent and Limitations of the Inspection and Testing: ☐ No remedial action is required ☐ The following observations are made:

Inspection Schedule Item No. or 'Test'	OBSERVATIONS	Classification Code C1, C2, C3 or FI (see below)
	<p>1) Could not locate main Gas to Confirm E bond, but on Continuity it passed.</p> <p>2) no RCD test label (Rectified)</p> <p style="text-align: right;">John Mutch Building Services Ltd 218 Holburn Street Aberdeen AB10 6DB phone: 01224 861999</p>	FI
One of the adjacent Codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.	<p>Danger present. Risk of injury. Immediate action required.</p> <p>Potentially dangerous – urgent remedial action required.</p> <p>Improvement recommended.</p> <p>Further investigation required without delay.</p>	<p>C1</p> <p>C2</p> <p>C3</p> <p>FI</p>
<input type="checkbox"/> Additional observations are recorded on the following number of continuation sheet(s)		

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
ITEM No.	DESCRIPTION										OUTCOME			
	John Mutch Building Services Ltd 218 Holburn Street Aberdeen AB10 6DB phone: 01224 861999										Use codes above. Provide additional comment where appropriate. C1,C2,C3 and FI coded items to be recorded in Section K of the Condition Report			
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)													
1.1	Service cable										✓			
1.2	Service head										✓			
1.3	Earthing arrangement										✓			
1.4	Meter tails										✓			
1.5	Metering equipment										✓			
1.6	Isolator (where present)										N/A			
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)													
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chapter 54)													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										✓			
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3; 542.2)										✓			
3.3	Provision of earthing / bonding labels at all appropriate locations (514.13)										✓			
3.4	Presence, condition & accessibility of earthing conductor at main earthing terminal (542.3; 543.3.2)										✓			
3.5	Confirmation of earthing conductor size (542.3; 543.1.1)										✓			
3.6	Presence, condition & accessibility of main protective bonding conductors & connections (543.3.2; 544.1)										✓			
3.7	Confirmation of main protective conductor sizes (544.1)										✓			
3.8	Presence, condition & accessibility of other protective bonding conductors & connections (543.3.1; 543.3.2)										✓			
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)													
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)										✓			
4.2	Security of fixing (134.1.1)										✓			
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓			
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 421.1.6; 526.5)										✓			
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)										✓			
4.6	Presence of main linked switch (as required by 462.1.201)										✓			
4.7	Operation of main switch (functional check) (643.10)										✓			
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (643.10)										✓			
4.9	Correct identification of circuit details and protective devices (514.8; 514.9)										✓			
4.10	Presence of RCD six-monthly test notice at or near consumer unit / distribution board (514.12.2)										✓			
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)										N/A			
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)										N/A			
4.13	Presence of other required labelling (please specify) (Section 514)										✓			
4.14	Compatibility of protective devices, bases & other components; correct type & rating (no signs of unacceptable thermal damage, arcing or overheating) (Sections 411, 421, 432, 433; 536.4.203)										✓			
4.15	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)										✓			
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.5; 522.8.11)										✓			
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5)										✓			
4.18	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5; 531.3)										✓			
4.19	RCD(s) provided for additional protection/requirements - includes RCBOs (415.1) See item 5.12										✓			
4.20	Confirmation of indication that SPD is functional (651.4)										✓			
4.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)										✓			
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A			
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A			

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
ITEM No.	John Mutch Building Services Ltd 218 Holburn Street Aberdeen AB10 6DB phone: 01224 861999										OUTCOME Use codes above. Provide additional comment where appropriate. C1,C2,C3 and FI coded items to be recorded in Section K of the Condition Report			
DESCRIPTION														
5.0 DISTRIBUTION / FINAL CIRCUITS														
5.1	Identification of conductors (Section 514)										✓			
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)										LIM			
5.3	Condition of insulation of live parts (416.1)										✓			
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1; 526.8) To include the integrity of conduit and trunking systems (metallic and plastic)										N/A			
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓			
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										✓			
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)										✓			
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; Section 543)										✓			
5.9	Wiring system(s) appropriate for the type & nature of the installation & external influences (Section 522)										N/A			
5.10	Concealed cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)										LIM			
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6)										LIM			
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA (415.1)													
	a) for all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3)										✓			
	b) for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										N/A			
	c) for cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)										LIM			
	d) for cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)										LIM			
	e) for final circuits supplying luminaires within domestic (household) premises (411.3.4)										✓			
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										LIM			
5.14	Band II cables segregated / separated from Band I cables (528.1)										LIM			
5.15	Cables segregated / separated from communications cabling (528.2)										LIM			
5.16	Cables segregated / separated from non-electrical services (528.3)										LIM			
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report													
	a) Connections soundly made and under no undue strain (526.6)										✓			
	b) No basic insulation of a conductor visible outside enclosure (526.8)										✓			
	c) Connections of live conductors adequately enclosed (526.5)										✓			
	d) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)										✓			
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(v))										✓			
5.19	Suitability of accessories for external influences (512.2)										N/A			
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)										✓			
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)										✓			
6.0 LOCATION(S) CONTAINING A BATH OR SHOWER (SECTION 701)														
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)										✓			
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										✓			
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)										✓			
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)										✓			
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)										LIM			
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										✓			
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)										✓			
6.8	Suitability of current-using equipment for particular position within the location (701.55)										✓			
7.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS														
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)										N/A			

EICR 190077

DB Reference No. *DB*

DB Location & Type *Cupboard under Stairs*

Details of circuits and/or installed equipment vulnerable to damage when testing

DB Location & Type Cupboard under Stairs.....

Phase sequence confirmed (where appropriate)

Z_s at DB 0.34 Ω
 I_{pi} at DB 699 kA
 Correct supply polarity confirmed ☒

☒ Correct supply polarity confirmed

CIRCUIT DETAILS

[illegible]

† Insert Reference Method (see Table 4A2 from BS 7671 Appendix 4)

#IB test voltage 500 V DC unless stated in 'Remarks'

*Includes BCD and/or AEND test buttons

TEST INSTRUMENTS USED

Manufacturer	Type	Serial No.	Date Accuracy Verified	Manufacturer	Type	Serial No.	Date Accuracy Verified	Manufacturer	Type	Serial No.	Date Accuracy Verified
FLUKE	1652B	1021001	30/8/19								

2018 Tested by: NAME (CAPITALS) *LEE FRASER*

Signature Date

Page 5 of