

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
ITEM No.	DESCRIPTION													OUTCOME
														Use codes above. Provide additional comment where appropriate. C1,C2,C3 and FI coded items to be recorded in Section K of the Condition Report
5.0	DISTRIBUTION / FINAL CIRCUITS													
5.1	Identification of conductors (514.3.1)													✓
5.2	Cables correctly supported throughout their run (522.8.5)													N/V
5.3	Condition of insulation of live parts (416.1)													✓
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)													
	a) To include the integrity of conduit and trunking systems (metallic and plastic)													N/A
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)													✓
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)													✓
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)													✓
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)													✓
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)													✓
5.10	Concealed cables installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)													N/V
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Section D. <i>Extent and limitations</i>) (522.6.201; 522.6.204)													N/V
5.12	Provision of additional protection by RCD not exceeding 30 mA													
	a) for all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)													✓
	b) for supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)													N/A
	c) for cables concealed in walls at a depth of less than 50 mm(522.6.202; 522.6.203)													N/V
	d) for cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)													N/V
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)													N/V
5.14	Band II cables segregated / separated from Band I cables (528.1)													N/V
5.15	Cables segregated / separated from communications cabling (528.2)													N/V
5.16	Cables segregated / separated from non-electrical services (528.3)													N/V
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)													
	a) Connections soundly made and under no undue strain (526.6)													✓
	b) No basic insulation of a conductor visible outside enclosure (526.8)													✓
	c) Connections of live conductors adequately enclosed (526.5)													✓
	d) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)													✓
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))													✓
5.19	Suitability of accessories for external influences (512.2)													N/A
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)													✓
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)													✓
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)													C3
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)													N/A
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)													✓
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)													✓
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)													✓
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)													✓
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)													✓
6.8	Suitability of current-using equipment for particular position within the location (701.55)													N/A
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)													N/A