



Contractor's Reference Number

CRN/

TYPE OF INSTALLATION

Tick appropriate box

Domestic dwelling

Highway Installation

Leisure Accommodation

Vehicle

Modular dwelling

Transportable unit

DETAILS OF THE CLIENT

Client: STONEHOUSE LETTINGS

Address: OSBORNE HOUSE
27-30 CARDEN PLACE
ABERDEEN

Postcode: AB10 1UP

PURPOSE OF THE REPORT

Purpose for which this report is required:

SAFETY CHECK

Date(s) on which inspection and testing were carried out:

DETAILS OF THE INSTALLATION

Occupier:

Address:

5c QUEENS LANE SOUTH

Postcode:

Estimated age of the electrical installation:

10+

years

Evidence of alterations or additions

If yes, estimated age

Date of previous inspection:

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:

Records of installation available:

Records held by:

Original (To the person ordering the work)

This report is not valid if the serial number has been defaced or altered

DPN7/ 0391761

ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Confirming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:

All electrical circuits + 10% of electrical fittings

Agreed limitations including the reasons, if any, on the inspection and testing:

N/A

Agreed with:

Operational limitations including the reasons (see page No.)

N/A

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

UNSATISFACTORY

Summary of the condition of the installation continued on additional pages? No Yes Specify page No(s):

Overall assessment of the installation: ~~SATISFACTORY~~ UNSATISFACTORY* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required. Delete as appropriate

This report should have been reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it. (See declaration on page 2)

This report is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (July 2015)



This report is not valid if the serial number has been defaced or altered

DPN7/ 0391761

Original (To the person ordering the work)

ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at page 1:

There are no items adversely affecting electrical safety or The following observations and recommendations for action are made

Observation(s) include reference location as appropriate

Code †

1	NO REC PROTECTION FOR LIGHTS	C2
2	MAIN BOARD THAT IS IN CANT GET RESSD FOR ANY MORE	
	NOTE FOR NEW MAIN BOARD	
	10 WAY	

DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described on page 1, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is **UNSATISFACTORY/UNSATISFACTORY*** Delete as appropriate

at the time the inspection was carried out, and that it should be further inspected as recommended within the time interval given below.

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

INSPECTION, TESTING AND ASSESSMENT BY:

Signature:

Name: (CAPITALS) SHAWN WANG

Position: ELECTRICIAN

Date: 17 OCT 17

REPORT REVIEWED AND CONFIRMED BY:

Signature:

Name: (CAPITALS)

(Registered Qualified Supervisor for the Approved Contractor)

Date:

NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than:

5 YEARS
(Enter interval in terms of years or months, as appropriate)

provided that any items which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or FI (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable.

Immediate remedial action required for items:

Urgent remedial action required for items:

Further investigation required without delay for items:

Improvement recommended for items:

1+2

† One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action:

Code C1 'Danger present'. Risk of injury. Immediate remedial action required.

Code C2 'Potentially dangerous'. Urgent remedial action required.

Code C3 'Improvement recommended'.

Code FI 'Further investigation required without delay'.

Please see the reverse of this page for guidance regarding the Classification codes.

Please see the 'Guidance for Recipients on the Classification codes' on the reverse of this page.

ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS		Nature of supply parameters		Characteristics of primary supply overcurrent protective device(s)	
System type(s)	Number and type of live conductors	Number of sources	Nominal voltage(s)	BS(EN)	Short-circuit capacity
TN-S	1-phase (2-wire) ✓ 3-phase (3-wire) ✓	1	230 V	1761	73 kA
TN-C-S	Other		U ₀ (iii) 240 V	Type II	Confirmation of supply polarity ✓
TT	Please state		3-phase Prospective fault current, I _{pf} (iii)	Rated current 100 A	

PARTICULARS OF INSTALLATION AT THE ORIGIN		Main Switch/Switch-Fuse/Circuit-Breaker/RCD	
Means of earthing		Type BS(EN)	Voltage rating
Distributor's facility	Location	600/40/17	240 V
Installation earth electrode	Method of measurement	No of poles	Rated current, I _n
Earth rod(s), tape etc	Ω	2	100 A
Electrode resistance, R _a		Supply conductors material	RCD operating current, I _{Δn}
Ω		Copper	mA
Continuity/connection verified		Supply conductors csa	RCD operating time (at I _{Δn})*
Location (where not obvious)		16 mm ²	ms
			Rated time delay
			ms

VEHICLE DETAILS		Registration (motorhome)		VIN	
Type: Touring	Static	Motorhome	Model		
Tick boxes and enter details as appropriate					

PARTICULARS OF VEHICLE INSTALLATION OR TRANSPORTABLE UNITS		Means of earthing		Earthing and protective bonding conductors	
<input type="checkbox"/> Hook-up connection	<input type="checkbox"/> System type: TT	System type: TN-S	<input type="checkbox"/> TN-C-S*	Conductor material	Conductor continuity verified
Flexible supply cable	For direct connection	* Connection to a TN-C-S system requires supervision (see regulation 717.411.4)		Conductor csa	mm ²
Length	Installation earth electrode details:	Method of measurement	Measured earth fault loop impedance, Z _e	Conductor material	mm ²
m	Type (e.g. rods, tapes)	Ω	Ω	Conductor csa	mm ²
I _z	Electrode resistance, R _a	Location	Maximum permitted load	Conductor material	mm ²
A	Ω		kVA/Amps	Conductor csa	mm ²
(R ₁ +R ₂) _{CS}				Conductor material	mm ²
				Conductor csa	mm ²
				Conductor material	mm ²
				Conductor csa	mm ²

TRANSPORTABLE UNIT DETAILS		Description	
Model name and year			



This report is not valid if the serial number has been defaced or altered

DPN7/0391761

APPROVED CONTRACTOR

ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

DETAILS OF NICEIC APPROVED CONTRACTOR



Enrolment number: **607334**
 Branch number: (if applicable)
 Telephone number: **01224 900555**
 Email address:

Trading title: **MANAGED SPACE T/A LOMOND ABERDEEN PROPERTY SERVICES**
 Address: **OSBORNE HOUSE
 27-30 CARMON PLACE
 ABERDEEN**
 Postcode: **AB10 1UP**

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Item	Description	Outcome*	Item	Description	Outcome*
1.0	Condition/adequacy of distributor's/supply intake equipment†	✓	4.0	Consumer unit(s)	✓	4.23	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓
1.1	Service cable	✓	4.1	Adequacy of working space or access to consumer unit	✓	5.0	Distribution/final circuits	✓
1.2	Service head	✓	4.2	Security of fixing	✓	5.1	Identification of conductors	✓
1.3	Distributor's earthing arrangement	✓	4.3	Condition of enclosure(s) in terms of IP rating	✓	5.2	Cables correctly supported throughout their length	✓
1.4	Meter tails - Distributor/Consumer	✓	4.4	Condition of enclosure(s) in terms of fire rating	✓	5.3	Condition of insulation of live parts	✓
1.5	Metering equipment	✓	4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	✓
1.6	Means of main isolation (where present)	✓	4.6	Presence of linked main switch	✓	5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
2.0	Presence of adequate arrangements for other sources (microgenerators etc)	NA	4.7	Operation of main switch (functional check)	✓	5.6	Adequacy of protective devices; type and rated current for fault protection	✓
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	NA	4.8	Main switch capable of being secured in the OFF position	✓	5.7	Presence and adequacy of circuit protective conductors	✓
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	NA	4.9	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	5.8	Co-ordination between conductors and overload protective devices	✓
2.3	Presence of alternative/additional supply warning notice(s)	NA	4.10	Correct identification of circuits and protective devices	✓	5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓
3.0	Earthing and bonding arrangements	✓	4.11	Presence of RCD test notice at or near consumer unit	✓	5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	✓
3.1	Presence and condition of distributor's earthing arrangement	✓	4.12	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓		• installed in prescribed zones. Extent and limitations	✓
3.2	Presence and condition of earth electrode connection	✓	4.13	Presence of alternative or additional supply warning notice at or near consumer unit	✓		• incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Extent and limitations)	✓
3.3	Confirmation of adequate earthing conductor size	✓	4.14	Presence of next inspection recommendation label	✓	5.11	Provision of additional protection by RCD not exceeding 30 mA	✓
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	4.15	Presence of other required labelling (please specify)	✓		• for all socket-outlets of rating 20 A or less	✓
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	4.16	Examination of protective device(s) and bases(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓		• for mobile equipment not exceeding a rating of 32A for use outdoors	✓
3.6	Accessibility and condition of main protective bonding conductor connections	✓	4.17	Single-pole switching or protective devices in the line conductors only	✓		• for cables installed in walls or partitions at a depth of less than 50 mm	✓
3.7	Accessibility and condition of other protective bonding connections	✓	4.18	Protection against mechanical damage where cables enter consumer unit	✓		• for cables installed in walls / partitions containing metal parts regardless of depth	✓
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	4.19	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	✓		• slighting of bus shelters, telephone kiosks, town plans and the like	✓
			4.20	RCDs provided for fault protection – includes RCBOs	✓			
			4.21	RCDs provided for additional protection – includes RCBOs	✓			
			4.22	Confirmation of indication that SPD is functional	✓			

* All boxes must be completed.
 ✓ indicates Acceptable condition
 N/A indicates Not applicable
 Improvement recommended state C3
 † Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.
 ‡ Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection.
 § This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certisure LLP. Certisure LLP operates the ELECSA & NICEIC brands. © Copyright Certisure LLP (July 2015)

Original (To the person ordering the work)

ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Item	Description	Outcome*	Item	Description	Outcome*
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	✓	7.0	Current-using equipment (Permanently connected)	✓	9.0	Other special installations or locations - Part 7s	✓
5.13	Band II cables segregated/separated from Band I cables	✓	7.1	Condition of equipment in terms of IP rating	✓	9.1	List of all other special installations or locations, if any, present. (Record the results of any particular inspection and append separately).	✓
5.14	Cables segregated/separated from communications cabling	✓	7.2	Equipment does not constitute a fire hazard	✓			
5.15	Cables segregated/separated from non-electrical services	✓	7.3	Enclosure not damaged/deteriorated so as to impair safety	✓			
5.16	Termination of cables at enclosures (extent of sampling indicated on page 1 of the report)	✓	7.4	Suitability for the environment and external influences	✓			
	• Connections soundly made and under no undue strain	✓	7.5	Security of fixing	✓			
	• No basic insulation of a conductor visible outside enclosures	✓	7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire <i>List number and location of luminaires inspected. (Separate page)</i>	✓			
	• Connections of live conductors adequately enclosed	✓	7.7	Recessed luminaires (downlighters)	✓			
	• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓		• correct type of lamps fitted	✓			
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓		• installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	✓			
5.18	Suitability of accessories for external influences	✓		• no signs of overheating to surrounding building fabric	✓			
5.19	Adequacy of working space / accessibility to equipment	✓		• no signs of overheating to conductors/terminations	✓			
5.20	Single-pole devices for switching or protection in line conductors only	✓			✓			
6.0	Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)	✓	8.0	Location(s) containing a bath or shower	✓			
6.1	In general	✓	8.1	Additional protection by RCD not exceeding 30 mA	✓			
	• presence and condition of appropriate devices	✓		• for low voltage circuits serving the location	✓			
	• correct operation verified	✓		• for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓			
6.2	For isolation and switching for mechanical maintenance only	✓	8.2	Where used as a protective measure, requirements for SELV or PELV are met	✓			
	• capable of being secured in the OFF position where appropriate	✓	8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	✓			
	• acceptable location - state if local or remote from equipment being controlled where appropriate	✓	8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓			
	• clearly identified by position and/or durable marking(s)	✓	8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓			
6.3	For isolation only	✓	8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓			
	• warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	✓	8.7	Suitability of equipment for installation in a particular zone	✓			

SCHEDULE OF ITEMS INSPECTED PARTICULAR TO A LEISURE ACCOMMODATION VEHICLE OR A TRANSPORTABLE UNIT

Item	Description	Outcome*
10.0	Means of connection	✓
10.1	'Hook-up' connection arrangement (inlet, plug and connector)	✓
	• equipment complies with BS EN 60309-2	✓
	• acceptable condition	✓
10.2	Flexible 'hook-up' cable	✓
	• correct length and size (csa)	✓
	• acceptable type (to BS 7919) and condition	✓
10.3	Direct connection (to static vehicles)	✓
	• acceptable type of wiring system and condition	✓
	• correct size (csa)	✓
10.4	Presence of required identification/labelling	✓
	• instructions for the safe use of the caravan/transportable unit installation/supply	✓
	• indication of voltage (stated on or adjacent) to all extra-low voltage (ELV) socket-outlets	✓
10.5	Plugs and socket-outlets non-interchangeable with those of LV installation	✓
	All conductors adequately protected against mechanical damage	✓
10.6	All conductors adequately protected against mechanical stresses (e.g. vibration from vehicular motion)	✓

\$ Note: Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection

SCHEDULES AND ADDITIONAL PAGES

Additional pages, including data sheets for additional source(s):	Page No(s)	6
Schedule of Inspections:	Page(s) No 4, 5	6
Special installations or locations:	Page No(s)	6
The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.		
Schedule of Circuit Details for the Installation:	Page No(s)	6
Schedule of Test Results for the Installation:	Page No(s)	6

* All boxes must be completed
 ✓ indicates Acceptable condition
 LIM indicates a Limitation
 N/A indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state F1 (to determine whether danger or potential danger exists)
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and F1 coded items to be recorded in Page 2 of the report.
 This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (July 2015)

Original (To the person ordering the work)

CIRCUIT DETAILS

Circuit number	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max disconnection time (s) by BS 7671	Overcurrent protective devices		RCD Operating current, I _{Δn} (mA)	RCD (Ω)	Circuit impedances (Ω)				All circuits (At least one column to be completed)	Insulation resistance				Maximum measured earth fault loop impedance, Z _e (Ω)	RCD operating times		Test button operation (✓)	
					Live (mm ²)	Neutral (mm ²)		BS (EN)	Type			Rating (A)	Short-circuit capacity (kA)	R ₁ (Line) (mΩ)	R ₂ (Neutral) (mΩ)		R ₁ (R ₁ + R ₂) (mΩ)	R ₂ (mΩ)	Line/Line (MΩ)	Line/Neutral (MΩ)		Line/Earth (MΩ)	Neutral/Earth (MΩ)		at 1s (ms)
1	Down lights	A	100	21	1.5	1	4	6000A	B	6	582	50	724	704	264	✓	77								
2	UP lighting	A	100	22	1.5	1	4	11	B	6	582	36				✓	57								
3	Immersion	A	100	1	2.5	1.5	4	11	B	6	2.11	.1				✓	.29								
4	Boiler	A	100	1	2.5	1.5	4	11	B	6	2.11	.7				✓	.26								
5	Down lights	A	100	5	2.5	1.5	4	11	B	6	108	61	62	99	41		✓	.62							
6	UP lights	A	100	7	2.5	1.5	4	11	B	6	108	62	63	1.1	33		✓	.54							
7	KITCHEN	A	100	7	2.5	1.5	4	11	B	6	108	54	55	94	23		✓	.44							

Location of consumer unit: UTILITY
 Designation of consumer unit: Light & Power
 Prospective fault current at consumer unit: 1.1 kA

TEST INSTRUMENTS Test instruments (serial numbers) used

Multi-function: 907186
 Insulation resistance: Continuity
 Earth electrode resistance
 Earth fault loop impedance
 RCD

CODES FOR TYPE OF WIRING

A	Thermoplastic sheathed cables
B	Thermoplastic cables in metal conduit
C	Thermoplastic cables in non-metallic conduit
D	Thermoplastic cables in metal trunking
E	Thermoplastic cables in non-metallic trunking
F	Thermoplastic SWA cables
G	Thermoplastic SWA cables
H	Mineral insulated cables
0	(Other - please state)