Energy Performance Certificate

Address of dwelling and other details

FLAT 5/4 23 FINLAY DRIVE **GLASGOW** G31 2BD

Name of approved organisation: RICS

Mid-floor flat

Membership number: Date of certificate:

RICS158929 21 June 2011

Reference number:

2698-1001-7206-2529-8900

Type of assessment:

RdSAP, existing dwelling

Total floor area:

103 m²

Main type of heating and fuel:

Boiler and radiators, mains gas

This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2009 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO₂) emissions. CO₂ is a greenhouse gas that contributes to climate change.

Energy Efficiency Rating

	Current	Potential
Very energy efficient - lower running costs	100	
(92 plus) A		
(81-91) B	82	83
(69-80) C	02	
(55-68)		
(39-54)		
(21-38)		
(1-20) G		
Not energy efficient - higher running costs		
Scotland	EU Direct 2002/91/	

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

Environmental Impact (CO₂) Rating

						Current	Potentia
Very environ	mentally fri	endly - lo	wer CO _z en	nissions			
(92 plus)	A						
(81-91)		3				84	86
(69-80)		C					
(55-68)			D				
(39-54)			E				
(21-38)				F		.sa	
(1-20)					G		
Not environn	nentally frie	endly - hig	her CO₂ en	nissions			
Scotland			EU Direct 2002/91/l				

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO2) emissions. The higher the rating the less impact it has on the environment.

Approximate current energy use per square metre of floor area: 91 kWh/m² per year

Approximate current CO₂ emissions: 17 kg/m² per year

Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above.

1 Low energy lighting for all fixed outlets

A full energy report is appended to this certificate



Remember to look for the energy saving recommended logo when buying energy-efficient products. It's a