Energy Performance Certificate

Address of dwelling and other details

33E JAMES STREET Dwelling type: Top floor flat

RIVERSIDE Name of approved organisation: NHER Accreditation Scheme

STIRLING Membership number: NHER004514
FK8 1UG Date of certificate: 11-Oct-2010

Reference number: 9180-2121-0000-9500-8785
Type of assement: RdSAP, existing dwelling

Total floor area: 74 m²

Main type of heating and fuel: Boiler and radiators, mains gas

This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2005 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO₂) emissions. CO₂ is a greenhouse gas that contributes to climate change.

Energy Efficiency Rating Current | Potential Very energy efficient - lower running costs (92 plus) В (69 - 80)74 67 (55 - 68)(39 - 54)I F (21 - 38)G Not energy efficient - higher running costs **EU Directive** Scotland 2002/91/EC

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating, the more energy efficient the home is and the lower the fuel bills are likely to be.

Environmental Impact (CO₂) Rating Current | Potential Very environmentally friendly - lower CO2 emissions (92 plus) /A) (81 - 91)0.0 (69 - 80)0 64 (55 - 68) \mathbf{n} 60 E (39 - 54)E (1 - 20)6 Not environmentally friendly - higher CO, emissions **EU Directive** Scotland 2002/91/EC

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating, the less impact it has on the environment.

Approximate current energy use per square metre of floor area: 266 kWh/m² per year Approximate current CO₂ emissions: 48 kg/m² per year

Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above. Higher cost measures could also be considered and these are recommended in the attached energy report.

1 Increase loft insulation to 270 mm

3 Upgrade heating controls

2 Low energy lighting for all fixed outlets

A full energy report is appended to this certificate



Remember to look for the energy saving recommended logo when buying energy-efficient products. It's a

Information from this EPC may be given to the Energy Saving Trust to provide advice to householders or financial help available to improve home energy efficiency.