

## Certificate for completion of a small new installation - Declaration of conformity

BS 5266-1: 2016 Clause Reference	Competent person function D – Designer I – Installer V – Verifier		System conforms (If NO, record a deviation - see page 1 of this certificate)		
			YES	NO	N/A
<b>Check of categories and documentation</b>					
4.2	D,V	Are plans of the system available and correct?	✓		
6.7	D,V	Has the system been designed for the correct mode of operation category?	✓		
6.7	D,V	Has the system been designed for the correct emergency duration period?	✓		
Clause 11	D,V	Is a completion certificate available with photometric design data?			✓
Clause 11	D,I,V	Is an emergency lighting log book available and are the entries up to date?	✓		
<b>Check of design</b>					
4.1; 5.2.8	D,I,V	Are the correct areas of the premises covered to meet the risk assessment?	✓		
5.2.8	D,I,V	Are all hazards identified by the risk assessment covered?	✓		
5.2.8	D,I,V	Are there luminaires sited at the "points of emphasis"?	✓		
5.2.2	D,I,V	Is the spacing between luminaires compliant with authenticated spacing or design data?			✓
5.2.9	D,I,V	Are the emergency exit signs and escape route direction signs correct and the locations of other safety signs to be illuminated under emergency conditions identified?	✓		
6.1	D,I,V	Do all non-maintained luminaires operate on local final circuit failure?	✓		
6.3	D,V	Is there illumination from at least two emergency luminaires or exit signs with a usable downward light element in each section of the escape route?			✓
6.4	I,V	Are luminaires at least 2 metres above floor and avoiding smoke reservoirs?	✓		
5.2.8.5; 5.2.8.6	D,V	Are additional luminaires located to cover toilets, lifts, plant rooms etc?			✓
<b>Check of the quality of the system components and installation</b>					
6.7	D,I,V	Do the luminaires conform to BS EN 60598-2-22?	✓		
6.7	D,I,V	Do any converted luminaires conform to BS EN 60598-2-22?			✓
6.7	D,I,V	Do luminaires have a suitable degree of protection for their location?	✓		
Clause 8	I,V	Does the installation conform to the good practice defined in BS 7671?	✓		
8.2.12	D,I,V	Are any plugs or sockets protected against unauthorized use?			✓
<b>Test facilities</b>					
8.3.3	D,I,V	Are the test facilities suitable to test function and duration?	✓		
8.3.3	D,I,V	Are the test facilities safe to operate and do not isolate a required service?	✓		
8.3.3	D,I,V	Are the test facilities clearly marked with their function?	✓		
8.3.3	D,V	If an automatic test system is installed, does it conform to BS EN 62034?			✓
10.7	D,I,V	Is the responsible person trained and able to operate the test facilities and record the test results correctly?	✓		
<b>Final acceptance to be conducted at completion</b>					
Clause 12	D,I,V	Does the system operate correctly when tested?	✓		
10.7	D,I,V	Has adequate documentation been provided to the user?	✓		
10.7	D,I,V	Is the user aware of action they should take in the event of a test failure?	✓		

Name of competent person making the declaration of conformity (please print) ..... STEPHEN DUNN

Signature of competent person .....

For and on behalf of ..... D & G Electrical Services Date ..... 5/12/2021