

**CERTIFICATE OF DESIGN, INSTALLATION AND
COMMISSIONING OF FIRE DETECTION AND FIRE ALARM
SYSTEMS OF GRADE B, C, D, E OR F GRADE SYSTEMS**

Certificate Reference: 000606

1 DETAILS OF THE CLIENT	
Client:	Happylets
Address:	1287 Argyle Street, Glasgow, G3 8TL

2 DETAILS OF THE FIRE DETECTION SYSTEM	
Installation Address:	Flat G/1, 8 Niddrie Square, Glasgow, G42 8QE
Extent of the fire detection and alarm system covered by this certificate:	Hall and Lounge Smoke Alarm (Feb 2028). Kitchen Heat Alarm (Feb2028)
The installation is:	☒ New ☐ An addition ☐ An alteration

3 DESCRIPTION OF SYSTEM GRADE AND SYSTEM CATEGORY	
System Grade:	System Category:
B ☐ N/A ☐ C ☐ N/A ☐ D ☒ E ☐ N/A ☐ F ☐ N/A ☐	LD1 ☐ N/A ☐ LD2 ☒ LD3 ☐ N/A ☐ PD1 ☐ N/A ☐ PD2 ☐ N/A ☐

4 COMMISSIONING					
Test buttons checked	☒	Simulated smoke or aerosol test	☒	Dedicated circuit(s) provided	☒
All alarm warning devices operate	☒	Heat test	☒	Protected device labelled	☒
Silencing system checked	☒	Bedroom sound level (Clause 13.2)	☒	Audible and visual indication of mains failure	☒
Sound level test instrument model and serial No:		Serial No. of associated Electrical Installation or Minor Works Cert:			

5 USER INSTRUCTIONS	
I/We the undersigned declare that the occupier of the dwelling (or owner in the case of a house in multiple occupancy) has been provided with written information about essential aspects of the operation and maintenance of the system, as follows:	
Operation of the system	☒ The need to keep clear space around all detectors and manual call points
Action to be taken in the event of a fire alarm signal	☒ Special precautions relevant to any lithium batteries used in the system
Avoidance of false alarms and action in the event of a false alarm	☒ Checking the system on reoccupation of the dwelling after a vacation etc.
Warning that apparent false alarm from carbon monoxide detector may not be false alarm	☒ The need to avoid contamination of detectors by paint
Routine testing of the system	☒ As-fitted drawing
Servicing and maintenance of the system (including intervals at which any batteries should be replaced)	☒

6 CERTIFICATE OF DESIGN, INSTALLATION AND COMMISSIONING	
I/We, being the person(s) responsible (as indicated by my/our signature(s) below), for the design, installation, and commissioning of the fire alarm system, particulars of which are set out above, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of BS 5839: Part 6 for the system described above, except for the variations, if any, stated below:	
Variations (if any):	
The extent of liability of the signatory is limited to the work described above as the subject of this certificate.	
For the DESIGN, INSTALLATION AND COMMISSIONING of the system:	
Name:	Garry O Rourke
Position:	Electrician
Signature:	
Date:	22/09/2020

7 DETAILS OF THE ELECTRICAL CONTRACTOR	
Trading Title:	AA Electrical Services
Address:	5 Calderpark Road Glasgow
Registration Number (if applicable):	191178
Telephone Number:	01417640767
Postcode:	G717RG