Domestic Landlord / Homeowner Gas Safety Record

Date:	19th March 2021	Ref:	UL P951SC16163
Gas Safe Reg No:	569345	Serial no:	UL P951SC16162



Details of Registered Business				
Name: Stuart Fleming Plumbing & Heating				
Address: 66 Redford Road				
	Edinburgh			
	Midlothian			
Postcode:	EH13 0AE	Po		
Contact Number:	07818264867	Co		

Details of Landlord / Homeowner (or agent where appropriate)						
Name:	Umega Lettings					
Address: 10 Lister Square						
	Quartermile					
	Edinburgh					
	Midlothian					
Postcode:	EH3 9GL					
Contact Number:	0131 221 0888					

Details of Site				
Name: Cate Tattersall				
Address: 3 Flat 4 Moncrieff Terrace				
	Edinburgh			
	Midlothian			
Postcode: EH9 1NB				
Contact Number:	N/A			

	Appliance Details														
	Location	Туре	Manufacturer	Model	Owned by	Owned by Landlord		ance Inspected?	Flue Type						
1	Kitchen Compartment	Boiler	Worcester Bosch	Greenstar 28i Junio	or Yes	es		Yes							
2	Kitchen	Gas Hob	N/A	N/A	Yes	Yes			Flueless						
	Inspection Details														
	Operating Pressure (mbars) or heat input (kW/h)	Safety devices operating correctly?	Satisfactory Ventilation?	Visual condition of flue & termination.	Flue operation checks.	Combustion analyser reading.		Was appliance serviced?	Is appliance safe to use?						
1	27.48 kW/h	Yes	Yes	Pass	Pass	Passed		No	Yes						
2	19.2 mbars	Yes	Yes	N/A	N/A	N/A		N/A		N/A		N/A		No	Yes

Final check results				
Outcome of gas tightness test	Pass			
Is the main protective equipotential bonding satisfactory?	Yes			
Is the emergency control accessible?	Yes			
Satisfactory visual inspection of gas installation pipework?	Yes			
CO alarm fitted and working?	Yes			
Notes				
N/A				

		Label & Warning	Combustion Performance Readings					
Defects Identified	Remedial Work Details	Notice	Low			High		
			СО	CO ²	Ratio	СО	CO ²	Ratio
Flue externally possibly being obstructed by Ivy on side of building.Integral filling loop connected.Gas Meter contained in unvented compartment.	Cleared Ivy around Flue terminal to remove potential obstruction of Air intake.Advise Ivy to be completely removed.Advise	No	11	9.4	0.0001	132	9.8	0.0013
None	N/A	No	N/A	N/A	N/A	N/A	N/A	N/A

Next Inspection Is Due Before:

19th March 2022

	Record Issued By:					
Signature:	SIL	_				
Gas Engineer	Stuart Fleming					
Gas Safe Licence	4950226	19th March 2021				

Received By:						
Signature:	M					
Name	Cate Tattersall					
Position	Tenant	Date	19th March 2021			

This record can be used to document the outcome of checks and tests required by The Gas Safety (Installation and Use) (Amendment) Regulations 2018. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate. Unless specifically recorded no detailed inspection of the flue lining, construction or integrity has been performed. Registered Business / engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.