

MINOR ELECTRICAL INSTALLATION WORKS

Requirements For Electrical Installations - BS 7671
To be used only for minor electrical work which does not include the provision of a new circuit

Certificate Number:

1 DESCRIPTION OF THE MINOR WORKS

Client address:	HMO Scotland Ltd	Installation address:	3 (2F1) Gayfield Place Edinburgh, EH7 4AB
Description of the minor works: Investigated Unknown Circuits 1@DB1 and 4&6@DB2. Not Found so all 3x disconnected			
Details of departures from BS 7671:2018 as amended to 2022 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5). Where applicable, a suitable risk assessment(s) must be attached to the Certificate: None			
Date minor works completed:	28/06/2024	Risk assessment attached:	N/A
Comments on (including any defects observed in) the existing installation (Regulation 644.1.2): All C2s and FI rectified from previous EICR			

2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements:	TN-C-S <input type="checkbox"/>	TN-S <input type="checkbox"/>	TT <input type="checkbox"/>
Earth fault loop impedance at distribution board (Z_{db}) supplying the final circuit:	<input type="text"/> Ω		
Presence of adequate main protective conductors:	Earthing Conductor <input type="checkbox"/>		
Main protective bonding conductor(s) to:	Water <input type="checkbox"/>	Gas <input type="checkbox"/>	Oil <input type="checkbox"/>
	Structural Steel <input type="checkbox"/>	Other: <input type="text"/> N/A	

3 CIRCUIT DETAILS

DB Reference:	<input type="text"/>	DB Location and Type:	<input type="text"/>
Circuit Number:	<input type="text"/>	Circuit Description:	<input type="text"/>
Installation reference method:	<input type="text"/>	Number and size of conductors:	Live: <input type="text"/> mm ² cpc: <input type="text"/> mm ²
Circuit overcurrent protective device:	BS (EN): <input type="text"/>	Type:	<input type="text"/> Rating: <input type="text"/> A
RCD:	BS (EN): <input type="text"/>	Type:	<input type="text"/> Rating: <input type="text"/> A
		Rated residual operating current ($I_{\Delta n}$):	<input type="text"/> mA
AFDD:	BS (EN): <input type="text"/>	Rating:	<input type="text"/> A SPD: BS (EN): <input type="text"/>
		Type:	<input type="text"/>

4 TEST RESULTS FOR THE ALTERED OR EXTENDED CIRCUIT

Protective conductor continuity:	R1 + R2:	<input type="text"/> Ω	or R2:	<input type="text"/> Ω
Continuity of ring final circuit conductors:	L/L:	<input type="text"/> Ω	N/N:	<input type="text"/> Ω
			cpc/cpc:	<input type="text"/> Ω
Insulation resistance:	Test Voltage:	500 V	Live - Live:	<input type="text"/> $M\Omega$
			Live - Earth:	<input type="text"/> $M\Omega$
Polarity satisfactory:	<input checked="" type="checkbox"/>	Maximum measured earth fault loop impedance, Z_S : <input type="text"/> Ω		
RCD disconnection time at rated residual operating current:	<input type="text"/> ms	Satisfactory test button operation: <input checked="" type="checkbox"/>		
AFDD satisfactory test button operation:	<input type="checkbox"/>	Note: Not all AFDDs have a test button	SPD functionality confirmed:	<input type="checkbox"/>
			Note: Not all SPDs have visible functionality indication	

5 DECLARATION

I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works has been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations), amended to 2022, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:	Ideal Electrical Solutions (UK) Ltd		
Address:	4-5 Parsons Green Terrace Edinburgh	Registration Number (if applicable):	SELECT No. 42193
	Postcode: EH87AN	Telephone Number:	0131 258 2750
Name:	Jay Macleod	Position:	Engineer
		Signature:	<input type="text"/>
		Date:	28/06/2024
Report reviewed and confirmed by:	Name: Christopher Turner		
	Position:	Electrician	Signature: <input type="text"/>
		Date:	28/06/2024

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS

(to be appended to the Certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.

You should have received an 'original' Certificate and the person that issued the certificate should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the person that issued the certificate to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of BS 7671 at the time the Certificate was issued.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or person(s), competent in such work.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or Test. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.