# **Energy Performance Certificate**

# Address of dwelling and other details

151 Meikleriggs Drive

Paisley PA2 9JN Dwelling type:

Ground-floor flat

Name of approved organisation: RICS

Membership number: RICS055659 Date of certificate: 12 April 2012

Reference number: 0160-2509-4040-9992-6931
Type of assessment: RdSAP, existing dwelling

Total floor area: 45 m<sup>2</sup>

Main type of heating and fuel: Boiler and radiators, mains gas

# This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2009 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO<sub>2</sub>) emissions. CO<sub>2</sub> is a greenhouse gas that contributes to climate change.

## **Energy Efficiency Rating** Current Potential Very energy efficient - lower running costs (92 plus) (81-91) B C (69-80)70 (55-68) 62 (39-54) E F (21-38) G Not energy efficient - higher running costs EU Directive 2002/91/EC Scotland

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

#### Environmental Impact (CO<sub>2</sub>) Rating Current Potential Very environmentally friendly - lower CO₂ emissions A (92 plus) B (81-91) C (69-80)72 63 (55-68)D E (39-54) (21-38)G (1-20)Not environmentally friendly - higher CO₂ emissions

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating the less impact it has on the environment.

EU Directive 2002/91/EC

Approximate current energy use per square metre of floor area: 288 kWh/m² per year

Approximate current CO<sub>2</sub> emissions: 55 kg/m<sup>2</sup> per year

### Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above. Higher cost measures could also be considered and these are recommended in the attached energy report.

- 1 Cavity wall insulation
- 2 Low energy lighting for all fixed outlets
- 3 Upgrade heating controls

A full energy report is appended to this certificate



Remember to look for the energy saving recommended logo when buying energy-efficient products. It's a quick and easy way to identify the most energy-efficient products on the market.

Scotland

Information from this EPC may be given to the Energy Saving Trust to provide advice to householders on financial help available to improve home energy efficiency.

N.B. THIS CERTIFICATE MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED VERSION